

AIRFLOW DIRECTION INCORPORATED

PRODUCTS - "VISUAL ONLY" NEGATIVE/POSITIVE



Model ADI-69-V-N/P Manually Switchable Lifetime Warranty vs. Breakage!



Magnetic backed, 3.5 inch square laminated labels for Switchable Negative/Positive Mode Rooms.

These sturdy labels mount on the steel entry door to room. For wood doors or for painted walls, magnetic label mounts on an ADI-supplied adhesive backed matching magnetic sheet mounted to wall or wood door.

U.S. Patents 5291182; 5410298; 5661461; 5798697.
Canadian 2107396.

Duplication or production is unlawful

Model ADI-69-V-N/P MANUALLY SWITCHABLE NEGATIVE/POSITIVE ROOM (Airflow Direction Into or Out of Room)

Great for Vivariums where rooms may be infrequently switched between negative and positive pressure modes.

The ADI-69-V-N/P is the same as the visual only negative or positive unit, except it is shipped with a red and a green sphere and the wall labels are magnetic.

IMPORTANT NOTE: When the room is switched between modes, the tilt of the Indicator tube must be manually switched, the sphere manually changed and the magnetic corridor label switched. Unused sphere and label are stored in polyzip bag for future use.

So, when the room is used for **negative** mode, only the red sphere is used and the tube is tilted as per the ADI-69-V-N (negative room unit) instructions and the **NEGATIVE ROOM** magnetic label is placed on the steel door or wall plate.

When the room is used for **positive** mode, only the green sphere is used and the tube is tilted as per the ADI-69-V-P (positive room unit) instructions and the **POSITIVE ROOM** magnetic label is placed on the steel door or wall plate.

Same nice features as the negative-only and positive-only units, especially the ability to check the operation of the unit. Just open the door and the sphere should fall out into its failsafe mode position. Once the door is closed, the sphere should go back into its proper position as described on the label . . . **SIMPLE !**